



Single Top Plates - Code Notes

A single top plate is allowed under the International Residential Code (IRC), but it is an uncommon construction practice. Standard practice for exterior and interior wall framing is to use a double top plate to connect wall segments and to support framing above the plates.

Eliminating unnecessary wood framing within walls can increase the thermal efficiency of the wall system. Less framing allows more insulation to be installed and also eliminates hot and cold spots (from thermal bridging through the frame) within the wall system.

The single top plates must be adequately tied at joints, corners, and intersecting walls by at least a 3-inch x 6-inch, 0.036 inch-thick galvanized steel plate that is nailed to each wall or wall segment by six 8d nails on each wall segment. Rafters or joists bearing on a single top plate must be within 1 inch of center over the studs below. The top plate may be omitted over lintels that are similarly tied to adjacent wall sections with steel plates.

Interior, nonbearing walls may be 2-inch x 3-inch studs spaced 24 inches (610 mm) on center. Or, if not part of a braced wall line (a series of braced wall panels), 2-inch x 4-inch flat studs, 16 inches on center may be used. Interior, nonbearing walls must be capped with at least a single top plate and be fireblocked.

Plan Review

1. Verify that the wall framing details call out a single top plate and also specify the 3-inch x 6-inch, 0.036 inch-thick galvanized steel plate to be installed at each corner and wall segment. Also verify that the nailing exception is specified on the building plans.
2. Verify that the spacing for the roof framing is identical to that of the wall framing. For example, the roof framing must be spaced at 24 inches on center if the wall framing is also spaced at 24 inches on center. The rafter/roof trusses must be within 1 inch of being centered above the wall studs.
3. If the wall system supports a floor, verify that the floor joist spacing is identical with the wall stud spacing.

Field Inspection

1. Verify that the top plate is fastened to the studs (two 16d nails).
2. Verify that a 3-inch x 6-inch, 0.036 inch-thick galvanized steel plate is installed at each corner and wall segment and that six 8d nails are used to attach each side of the plate to the corner or wall segment.
3. Verify that the rafters or trusses used in the roof framing are within one inch of the center of each of the studs below.
4. Verify that the floor joists supported by the studs are within one inch of the center of the studs below.

Code Citations*

IRC 2000 and 2003, in Section R602.3.2 Top Plate

Exception: A single top plate may be installed in stud walls, provided that the plate is adequately tied at joints, corners, and intersecting walls by a minimum 3-inch-by-6-inch by 0.036 inch-thick (76



mm by 152 mm by 0.914 mm) galvanized steel plate that is nailed to each wall or segment of wall by six 8d nails on each side, provided that the rafters or joists are centered over the studs with a tolerance of no more than 1 inch (25.4 mm). The top plate may be omitted over lintels that are adequately tied to adjacent wall sections with steel plates or equivalent as previously described.

IRC 2000 and 2003, in Figure 602.3(2)

The figure label states "single or double top plate."

IRC 2000 and 2003, in Section R602.5

Interior, nonbearing walls shall be permitted to be constructed with 2-inch-by-3-inch (51 mm by 76 mm) studs spaced 24 inches (610 mm) on center or, when not part of a braced wall line, 2-inch-by-4-inch (51 mm by 102 mm) flat studs spaced at 16 inches (406 mm) on center. Interior, nonbearing walls shall be capped with at least a single top plate. Interior, nonbearing walls shall be fireblocked in accordance with Section R602.8.

IRC Table R602.3(1)

For top or sole plate to stud (end nail), two 16d fasteners are required.

*Copyright, 2000, [International Code Council](#) (html,), Inc. Falls Church, Virginia. *2000 International Residential Code*; and Copyright, 2003, [International Code Council](#) (html,), Inc. Falls Church, Virginia. *2003 International Residential Code*. Reproduced with permission. All rights reserved.